

Appendix C All Results

Sample ID	Collection Date	Collection Location	Concentration (ug/L)
Holmdel High School			
HSCA1	04/15/2022	Culinary Arts Sink 1	3.38
HSCA2	04/15/2022	Culinary Arts Sink 2	1.68
HSCA3	04/15/2022	Culinary Arts Sink 3	3.52
HSCA4	04/15/2022	Culinary Arts Sink 4	3.88
HSCA5	04/15/2022	Culinary Arts Sink 5	2.01
HSCA6	04/15/2022	Culinary Arts Sink 6	4.34
HSCAFE1	04/15/2022	Café Lounge Sink	2.85
HSCC1	04/15/2022	Serving Area Coffee Machine	<1.00
HSCCSCM	04/15/2022	Café Lounge Coffee Machine	<1.00
HSCSKS	04/15/2022	Café Lounge Sink	1.71
HSF1	04/15/2022	Fountain outside Wrestling Room	<1.00
HSF1A	04/15/2022	Commons Fountain A	<1.00
HSF11	04/15/2022	Main Office Fountain	2.23
HSF12	04/15/2022	Fountain 1 in 400 Hallway	<1.00
HSBF1	04/15/2022	Bottle Fill outside Wrestling Room	<1.00
HSF15	04/15/2022	Fountain in 800 Hallway	<1.00
HSF16	04/15/2022	Fountain 2 in 400 Hallway	<1.00
HSF17	04/15/2022	Fountain 1 outside Auditorium	2.06
HSF18	04/15/2022	Fountain 2 outside Auditorium	2.04
HSF19	04/15/2022	Fountain 3 outside Auditorium	<1.00
HSBF12	04/15/2022	Bottle Fill 1 in 400 Hallway	<1.00
HSF23	04/15/2022	Fountain 1 in 500 Hallway	<1.00
HSF1B	04/15/2022	Commons Fountain B	<1.00
HSF25	04/15/2022	Fountain in 900 Hallway	<1.00
HSF26	04/15/2022	Fountain 2 in 500 Hallway	<1.00
HSF27	04/15/2022	Fountain in Girls Locker Room	4.47

HSF3	04/15/2022	Fountain near Old Gym Washroom	<1.00
HSF4	04/15/2022	Fountain in Boys Locker Room	3.10
HSF5	04/15/2022	Fountain 1 in New Gym Hallway	1.53
HSF6	04/15/2022	Fountain 2 in New Gym Hallway	1.23
HSF7	04/15/2022	Fitness Center Fountain 1	<1.00
HSF8	04/15/2022	Fitness Center Fountain 2	<1.00
HSBFA	04/15/2022	Commons Bottle Fill A	<1.00
HSF01	04/15/2022	Facilities Building Sink	<1.00
HSF02	04/15/2022	Facilities Building Water Cooler	<1.00
HSGB1	04/15/2022	Grounds Bay Sink	1.51
HSGYM1	04/15/2022	Old Gym Water Fountain	<1.00
HSGYM2	04/15/2022	Old Gym Bottle Fill	<1.00
HSGYM1C1	04/15/2022	Old Gym Ice Machine	<1.00
HSMOWC	04/15/2022	Main Office Water Cooler	<1.00
HSM01	04/15/2022	Main Office Sink	6.06
HSNS1	04/15/2022	Nurse Station Sink 1	3.76
HSNS2	04/15/2022	Nurse Station Sink 2	1.82
HSPE1	04/15/2022	Physical Education Office Sink	5.27
HSBFB	04/15/2022	Commons Bottle Fill B	<1.00
HSBF16	04/15/2022	Bottle Fill 2 in 400 Hallway	<1.00
HSTR1	04/15/2022	Training Room Slop Sink	3.04
HSTRICE	04/15/2022	Training Room Ice Machine	<1.00
HSF20	04/15/2022	Fountain 4 outside Auditorium	1.92
HSBF23	04/15/2022	Bottle Fill 1 in 500 Hallway	<1.00
HSBF26	04/15/2022	Bottle Fill 2 in 500 Hallway	<1.00
HS-OGS-OLD GYM	04/15/2022	Old Gym Washroom Sink	7.92
HS-SRS	04/15/2022	Blank	<1.00
Indian Hill School			
IH-CS1	04/16/2022	Custodial Office Sink	3.08
IH-F1	04/16/2022	Fountain 1 outside Gym A	<1.00
IH-F10	04/16/2022	Room 7 Fountain	7.90

IH-F11	04/16/2022	Room 8 Fountain	10.6
IH-F12	04/16/2022	Room 9 Fountain	10.7
IH-WF1	04/16/2022	Fountain 2 outside Gym A	<1.00
IH-F14	04/16/2022	Room 11 Fountain	<1.00
IH-F15	04/16/2022	Room 12 Fountain	5.56
IH-F16	04/16/2022	Room 15 Fountain	5.67
IH-F17	04/16/2022	Room 16 Fountain	17.9
IH-F18	04/16/2022	Room 17 Fountain	4.87
IH-F19	04/16/2022	Room 18 Fountain	13.8
IH-F20	04/16/2022	Room 19 Fountain	12.4
IH-F21	04/16/2022	Room 20 Fountain	5.43
IH-F2	04/16/2022	Fountain outside Gym B	<1.00
IH-BF1	04/16/2022	Bottle Fill outside Gym A	<1.00
IH-F23	04/16/2022	Room 22 Fountain	2.03
IH-F-L31	04/16/2022	Fountain 1 outside Bathroom L-3	<1.00
IH-F25	04/16/2022	Girls Locker Room Fountain 2	8.48
IH-F26	04/16/2022	Boys Locker Room Fountain 1	5.28
IH-F27	04/16/2022	Boys Locker Room Fountain 2	5.29
IH-F-L32	04/16/2022	Fountain 2 outside Bathroom L-3	<1.00
IH-F-R10	04/16/2022	Room 10 Fountain	2.59
IH-F3	04/16/2022	Room 26 Fountain	5.20
IH-F30	04/16/2022	Fountain outside Room 132	<1.00
IH-F31	04/16/2022	Bottle Fill outside Room 132	<1.00
IH-F32	04/16/2022	Fountain 1 outside Room 232	2.55
IH-F33	04/16/2022	Fountain 2 outside Room 232	1.15
IH-MOS	04/16/2022	Main Office Sink	22.9
IH-F35	04/16/2022	Band Room Fountain	56.7
IH-F36	04/16/2022	Fountain 1 between bathrooms and kitchen	<1.00
IH-F37	04/16/2022	Fountain 2 between bathrooms and kitchen	<1.00
IH-F-R13	04/16/2022	Room 13 Fountain	1.92
IH-F4	04/16/2022	Room 1 Fountain	5.04
IH-F-414	04/16/2022	Room 14 Fountain	23.7
IH-F5	04/16/2022	Room 2 Fountain	12.4
IH-F6	04/16/2022	Room 3 Fountain	4.32

IH-F7	04/16/2022	Room 4 Fountain	2.39
IH-F8	04/16/2022	Room 5 Fountain	5.63
IH-F9	04/16/2022	Room 6 Fountain	8.52
IH-KS1	04/16/2022	Kitchen Sink 1	4.03
IH-KS2	04/16/2022	Kitchen Sink 2	<1.00
IH-KS3	04/16/2022	Kitchen Sink 3	1.81
IH-KS4	04/16/2022	Kitchen Sink 4	5.24
IH-KS5	04/16/2022	Kitchen Sink 5	1.25
IH-LS1	04/16/2022	Library Sink 1	2.45
IH-LS2	04/16/2022	Library Sink 2	2.46
IH-MA	04/16/2022	Music Room A Sink	3.48
IH-NO1	04/16/2022	Nurse Office Sink 1	6.35
IH-NO2	04/16/2022	Nurse Office Sink 2	<1.00
IH-TL	04/16/2022	Upstairs Teacher Lounge Sink	<1.00
IH-WC	04/16/2022	Upstairs Teacher Lounge Water Cooler	<1.00
IH-BF2	04/16/2022	Bottle Fill outside Gym B	<1.00
IH-S-420	04/16/2022	Blank	<1.00
Village School			
V-MAIN 1	04/16/2022	Water Main	606
V-MO1	04/16/2022	Main Office Sink 1	4.71
V-MO2	04/16/2022	Main Office Sink 2 (Observation Room)	1.44
V-MO3	04/16/2022	Main Office Sink 3	<1.00
V-N1BR	04/16/2022	Nurse Break Room Sink	2.82
V-N1I	04/16/2022	Nurse Island Sink	3.06
V-N1W	04/16/2022	Nurse Wall Sink	4.41
V-POE	04/16/2022	Custodial Office Sink	1.21
V-TR	04/16/2022	Teacher Lounge Sink	<1.00
VF1	04/16/2022	Main Entrance Fountain 1	<1.00
VF10	04/16/2022	Room 128 Fountain	<1.00
VF11	04/16/2022	Fountain outside Room 121/134	<1.00
VF12	04/16/2022	Bottle Fill outside Room 121/134	<1.00
VF13	04/16/2022	Room 121 Fountain	1.09
VF14	04/16/2022	Room 134 Fountain	9.45
VF15	04/16/2022	Room 127 Fountain	1.21
VF16	04/16/2022	Room 126 Fountain	2.17
VF17	04/16/2022	Room 125 Fountain	<1.00
VF18	04/16/2022	Room 124 Fountain	40.0
VF19	04/16/2022	Room 123 Fountain	<1.00
VF2	04/16/2022	Main Entrance	<1.00

		Fountain 2	
VF20	04/16/2022	Room 120 Fountain	<1.00
VF21	04/16/2022	Room 119 Fountain	<1.00
V-F-135	04/16/2022	Room 135 Fountain	5.46
VF23	04/16/2022	Room 117 Fountain	4.25
VF-136	04/16/2022	Room 136 Fountain	<1.00
V-F-OMR	04/16/2022	Fountain outside Music Room 112	2.10
VF26	04/16/2022	Room 139 Fountain	5.62
V-S-420	04/16/2022	Blank	<1.00
VF28	04/16/2022	Room 102 Fountain	2.01
VF29	04/16/2022	Room 104 Fountain	7.75
VF3	04/16/2022	Main Entrance Fountain 3	<1.00
VF30	04/16/2022	Room 106 Fountain	1.78
VF31	04/16/2022	Room 108 Fountain	3.06
VF32	04/16/2022	Room 110 Fountain	1.20
VF33	04/16/2022	Room 109 Fountain	1.43
VF34	04/16/2022	Room 107 Fountain	1.58
VF35	04/16/2022	Room 105 Fountain	1.22
VF36	04/16/2022	Room 103 Fountain	1.73
VF4	04/16/2022	Main Entrance Fountain 4	<1.00
VF40	04/16/2022	Room 40 Fountain	<1.00
VF41	04/16/2022	Room 38 Fountain	<1.00
VF42	04/16/2022	Room 39 Fountain	<1.00
VF43	04/16/2022	Room 37 Fountain	<1.00
VF45	04/16/2022	Fountain outside Room 40	2.75
VF46	04/16/2022	Room 36 Fountain	5.02
VF47	04/16/2022	Room 35 Fountain	<1.00
VF48	04/16/2022	Room 34 Fountain	1.46
VF49	04/16/2022	Room 33 Fountain	<1.00
VF5	04/16/2022	Room 141 Fountain	2.72
VF50	04/16/2022	Room 31 Fountain	<1.00
VF51	04/16/2022	Room 32 Fountain	<1.00
VF52	04/16/2022	Room 28 Fountain	<1.00
VF53	04/16/2022	Room 26 Fountain	<1.00
VF54	04/16/2022	Room 25 Fountain	<1.00
VF55	04/16/2022	Room 24 Fountain	<1.00
VF56	04/16/2022	Room 23 Fountain	1.12
VF57	04/16/2022	Room 19 Fountain	3.27
VF62	04/16/2022	Fountain outside Board Office	1.31
VF63	04/16/2022	Room 12 Sink	2.75
VF64	04/16/2022	Fountain outside old	1.77

		APR Room	
VF67	04/16/2022	Teacher Lounge Water Cooler	<1.00
VF66	04/16/2022	Room 48B Fountain	10.9
VF8	04/16/2022	Room 130 Fountain	<1.00
VF9	04/16/2022	Room 129 Fountain	7.75
V BOE S	04/16/2022	Room 12 Sink	3.02
V BOE WC	04/16/2022	Room 12 Water Cooler	<1.00
VK1	04/16/2022	Kitchen Sink 1	2.90
VK2	04/16/2022	Kitchen Sink 2	2.79
VK3	04/16/2022	Kitchen Sink 3	3.20
VK4	04/16/2022	Kitchen Sink 4	<1.00
VK5	04/16/2022	Kitchen Sink 5	12.7
VK6	04/16/2022	Kitchen Sink 6	20.7
VK7	04/16/2022	Kitchen Sink 7	6.44
VK8	04/16/2022	Kitchen Sink 8	1.72
W.R. Satz School			
WR-S-K1	04/15/2022	Kitchen Sink 1	3.60
WR-S-K2	04/15/2022	Kitchen Sink 2	<1.00
WR-S-K3	04/15/2022	Kitchen Sink 3	2.95
WR-S-K4	04/15/2022	Kitchen Sink 4	2.97
WR-S-K5	04/15/2022	Kitchen Sink 5	3.88
WR-S-K6	04/15/2022	Kitchen Sink 6	2.54
WR-S-K7	04/15/2022	Kitchen Sink 7	2.32
WR-S-K8	04/15/2022	Kitchen Sink 8	3.38
WR-K-ICE	04/15/2022	Kitchen Ice Machine	<1.00
WR-S104	04/15/2022	Room 104 Sink	22.2
WR-SF1	04/15/2022	Cafeteria Fountain	<1.00
WR-BF1	04/15/2022	Cafeteria Bottle Fill	<1.00
WR-SF11	04/15/2022	Fountain outside Room 126	97.0
WR-SF12	04/15/2022	Fountain outside Room 124	11.2
WR-SF13	04/15/2022	Fountain outside Room 137	10.8
WR-SF14	04/15/2022	Fountain outside Room 135	6.48
WR-SF15	04/15/2022	Fountain outside Room 104	4.43
WR-SF16	04/15/2022	Fountain outside Room 103	4.15
WR-SF17	04/15/2022	Fountain outside Room 106	83.5
WR-SF18	04/15/2022	Fountain outside Room 105	24.5
WR-SF19	04/15/2022	Girls Locker Room Fountain	<1.00

WR-SF2	04/15/2022	Fountain 1 outside Room 204	7.92
WR-SF3	04/15/2022	Fountain 2 outside Room 204	5.93
WR-SF4	04/15/2022	Fountain 1 outside Room 209	6.26
WR-SF5	04/15/2022	Fountain 2 outside Room 209	10.1
WR-SF6	04/15/2022	Boys Locker Room Fountain	<1.00
WR-SF7	04/15/2022	Fountain 1 outside Gym	<1.00
WR-SF8	04/15/2022	Fountain 2 outside Gym	<1.00
WR-SF9	04/15/2022	Fountain outside Room 115	78.8
WR-BF6	04/15/2022	Boys Locker Room Bottle Fill	<1.00
WR-SLS1	04/15/2022	Life Skills Room Sink 1	9.53
WR-SLS2	04/15/2022	Life Skills Room Sink 2	2.84
WR-SLS3	04/15/2022	Life Skills Room Sink 3	2.23
WR-SLS4	04/15/2022	Life Skills Room Sink 4	4.48
WR-SLS5	04/15/2022	Life Skills Room Sink 5	4.15
WR-SMS1	04/15/2022	Maintenance Shop Sink	<1.00
WR-SNO	04/15/2022	Nurse Office Sink	3.47
WR-STL1	04/15/2022	Staff Lounge Sink	2.62
WR-BF19	04/15/2022	Girls Locker Room Bottle Fill	<1.00
WR-SF-MO	04/15/2022	Fountain Outside Main Office	<1.00
WR-BF-MO	04/15/2022	Bottle Fill Outside Main Office	<1.00
WR-SRS	04/15/2022	Blank	<1.00